



---

# METROPOLITAN WASHINGTON AIRPORTS AUTHORITY

**RFP-18-32181**

**Design Build Concourse C/D Electrical Ductbank Rehabilitation and Feeder Replacement Project at Washington Dulles International Airport**

April 22, 2019

Questions and Answers

**Notice: Questions may have been edited for clarity and relevance.**

- 1. Question: Has the Airports Authority conducted any previous video inspections of the conduits in question and are those videos available to prospective bidders.**

**Answer: MWAA has the video inspections for two (2) conduits between manholes 19EP6/19EP7 and two (2) conduits between manholes 19EP6/20EP15. These videos are available on the solicitation website (Pre-Proposal Conference Documents). Contractor shall consider all the ductbank to be rehabilitated in the scope has the similar condition as in the videos.**